



NOTES:

1. MINIMUM 2 CONNECTIONS BETWEEN PIPES AS SHOWN.
2. COAT ALL EXOTHERMIC WELDS WITH THE SAME APPROVED COATING MATERIAL AS FOR BOLTS. SEE DWG. No. 0201-0601-SD26, PROCEDURE 5.

REVISIONS

**MISSOURI AMERICAN WATER STANDARD
CIVIL
CONTINUITY BONDS FOR PUSH-ON
DUCTILE IRON PIPE DETAIL**

MISSOURI AMERICAN WATER
ST. LOUIS, MO. 63141

MISSOURI AMERICAN WATER ENGINEERING
727 CRAIG ROAD
ST. LOUIS, MO. 63141



AMERICAN WATER

DRAWN BY KKM
PROJECT ENG'R
APPROVED

DATE 11-13-08
PROJECT IP

USE DIMENSIONS ONLY
SCALE N.T.S.

USE APPROVED DRAWINGS ONLY
FOR CONSTRUCTION PURPOSES

0201-0601-SD25