



NOTES:

1. CENTER METER IN BOX, MIN 3" CLEARANCE ON ALL SIDES.
2. TRENCH, INSTALL, AND BACKFILL SERVICE LINE IN ACCORDANCE WITH AW SPECIFICATIONS.
3. POINT OF DEMARCATION FOR SERVICE LINE OWNERSHIP PER PRIME CONTRACT BETWEEN AW AND GOVERNMENT.
4. SERVICE LINE MATERIALS SHALL MEET AW SPECIFICATIONS.
5. PROVIDE TRACE WIRE ALONG WATER SERVICE LINE. TRACE WIRE SHALL EXTEND INTO THE CURB BOX AND METER PIT AND TERMINATE IN THE METER PIT.
6. IF WATER SERVICE BETWEEN MAIN AND WATER METER IS REPLACED WITH NON-METALLIC PIPING, THERE SHALL BE A MINIMUM LENGTH OF TEN (10) FT OF METALLIC PIPING BETWEEN THE BUILDING STRUCTURE AND METER PIT TO MAINTAIN PROPER GROUNDING OF BUILDING'S ELECTRICAL SYSTEM.

WATER SERVICE INSTALLATION (FOR SERVICE LINES SMALLER THAN 2")

REVISIONS
5/10 - MSG EDITS
1/12 - MSG EDITS
7/12 - MSG EDITS
6/13 - MSG EDITS
7/14 - MSG EDITS
1/16 - MSG EDITS

AMERICAN WATER MILITARY SERVICES GROUP
CIVIL
SMALLER THAN 2" WATER
SERVICE INSTALLATION DETAIL

AMERICAN WATER MILITARY SERVICES GROUP
CAMDEN, NJ 08102

AMERICAN WATER M.S.G.
1 WATER STREET
CAMDEN, NJ 08102



DRAWN BY Z. ALAM
PROJECT ENG'R PDK
APPROVED

DATE 05-03-2010
PROJECT N/A

USE DIMENSIONS ONLY
SCALE N.T.S.

USE APPROVED DRAWINGS ONLY
FOR CONSTRUCTION PURPOSES

MSG-W-01A

FINAL

MSG-W-01A