



- NOTES:
- 1) ALL EXTERIOR BOLTS, COLLARS & RODS ARE TO BE COMPLETELY COVERED USING FIELD APPLICATION OF SPRAY ON BITUMASTIC MATERIAL EQUAL TO 3M AUTOMOTIVE UNDERCOATING.
  - 2) ALL PARTS AND PIPELINE ON THE OUTSIDE OF THE VAULT SHALL BE ENCASED WITH 12 MIL POLYETHYLENE TUBE MEETING REQUIREMENTS OF AWWA C105.
  - 3) ALL FLUOROPOLYMER PTFE COATINGS SHALL BE BAKED ON OR THERMALLY SET BY THE COATING MANUFACTURE.

MB-001  
 SUBJECT TO REVISION WITHOUT NOTICE 08-28-2020

**INSULATED FLANGE CONNECTION DETAIL**