

Montross-Driftwood Beach

Typical Water Quality Information

PWSID Number: VA4193360

Area Served: Montross-Driftwood Beach (Zip code: 22520)

Where Does My Water Come From?

The source of your drinking water is groundwater. The 2 wells draw water from the Potomac aquifer.

Average amount of water supplied to customers on a daily basis

22,000 gallons per day

| Parameter | Average or Range | Comments |
|--------------------------------------------------------------|---------------------|----------------------------------------------------------------------------------------|
| рН | 8.5 | Measure of the acid/base properties of water |
| Fluoride | 1.78 mg/L | Naturally occurring and water additive, MCL = 4.0 mg/L |
| Sodium | 145.4 mg/L | Naturally occurring from erosion of natural deposits No MCL – Informational only |
| Iron | ND | Naturally occurring Secondary Standard Limit = 0.3 mg/L |
| Manganese | ND | Naturally occurring from erosion of natural deposits |
| Type of disinfection | N/A | chlorine |
| Disinfectant residual level in the distribution system | 0.44 – 1.84 mg/L | Water additive to control microbes |

| Parameter | Average or Range | Comments |
|------------------------------------------------|---------------------|--------------------------------------------------------------------------------------------------------------------|
| Lead [90 th percentile result] | 3 ug/L | Corrosion of household plumbing; erosion of natural deposits Action Level = 15 ug/L |
| Copper [90 th percentile result] | 0.133 mg/L | Corrosion of household plumbing; erosion of natural deposits Action Level = 1.3 mg/L |
| Alkalinity | 300 mg/L | Natural calcium / magnesium content in the water |
| Hardness | 16 mg/L | Ability of water to neutralize acid and bases and maintain a stable pH |
| Nitrate | ND | Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits MCL = 10 mg/L |
| Arsenic | 0.001 mg/L | MCL = 0.010 mg/L |

Definitions

- mg/L milligrams per liter; one milligram per liter is equal to one part per million (ppm), which
 is approximately the same as 1 second in 11.5 days
- ug/L micrograms per liter; one microgram per liter is equal to one part per billion (ppb), which is approximately the same as 1 second in 31.7 years
- N/A not applicable
- ND not detected
- MCL Maximum Contaminant Level the highest level of a contaminant allowed in drinking water under State and Federal regulations

For a complete report of your water quality, please refer to the Water Quality Report located on the American Water web site. <u>www.amwater.com/ccr/driftwoodbeach.pdf</u>

For more information on your water quality, please contact Kelly Ryan, Water Quality Supervisor, at 804-446-9822

> Other inquiries should be directed to our Customer Service Center at 1-800-452-6863